

VOC Content Test Certificate

Wednesday August 24th, 2011

Manufacturer: Promat Australia (1 Scotland Road, Mile End, SA 5031)

Sample Description: PROMASEAL® AN Fire Rated Acrylic Sealant

Date Tested: August 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">PROMASEAL® AN Fire Rated Acrylic Sealant</p>
<p>Architectural sealant 250 grams per Litre as VOC content material</p>	<p>10 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV110805