


Australia Declaration of Conformance (AUDoC)

Responsible Supplier Details

Name:	Voltex Electrical Accessories Pty Ltd
Contact Address:	38-44 Panalatinga Road Old Reynella, SA 5161 Australia
Telephone:	+61 (8) 8374 4200
Email:	sales@voltexelectrical.com.au
ABN:	81 097 390 933
Web:	www.voltexelectrical.com.au
Responsible Supplier Code:	E787

Product Details

Product type:	Wall Switch
Product description:	Architrave Switch
Trade name:	 (Voltex)
Item number(s):	CSW1A, CSW2A, CSW3A, CSW4A, CSW1AB, CSW2AB, CSW3AB and CSW4AB
Electrical rating:	250V~, 16AX, M80, SBL 200W, IP20 Two-way, single-pole switch; Rocker switch; Flush-type; Screw-type tunnel terminals for direct connection to fixed wiring of an installation (terminal screw $\Phi 3.5\text{mm}$) Contact gap $\geq 1.2\text{mm}$; Insulating material Class 80 No field-installed insulation
Standard(s) applied:	
AS 3133:2020 +A1:2024 with AS/NZS 3100:2022 +A1:2023	
Report/ Certification Number	Date Issued (expiry date)
Refer Voltex Electrical Product Compliance Review EPCR-CSWxA-00	04-06-2025
Global-Mark Pty Ltd, Certificate of Conformity, GMA-511875-EA Rev 03	26-05-2025 (08-02-2027)
Relevant Comments and Conditions	
'CSW' denotes Classic style wall switch; '1', '2', '3' or '4' denotes 1, 2, 3 or 4 gang switch; 'B' denotes black instead of white colour 2025/05/26 Modification 3 Add alternative models of architrave range: CSW1A, CSW2A, CSW3A, CSW4A, CSW1AB, CSW2AB, CSW3AB & CSW4AB	
EESS Equipment Registration	Length (expiry date)
E2022066062	20 months (10-02-2027)

Australia Declaration of Conformance (AUDoC)**Declaration of Conformance**

We Voltex Electrical Accessories Pty Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the above-mentioned standard(s) or other normative document(s) and have determined that it:
 - Complies with the essential safety characteristics and requirements for electrical equipment set out in AS/NZS 3820; and
 - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Andrew Gore
Position:	Compliance Advisor Authorised Representative
Date:	04-06-2025
Signature:	