

Resetting the kWh counters on the Voltex EM-40 Energy Meter

The EM-40 kWh counters can be reset to 0kWh using the settings menu. This is accessed from the touch button on the front of the EM-40.



Touch button

A **Long touch** (between 1 second and 4 seconds) is used to choose a menu option, or to confirm an action.
A **Short touch** (less than 1 second) is used to move to the next menu option.

Step 1 - Enter the setting menu

Long touch the touch button once. After 1 second, when the display starts blinking, let go of the touch button. After releasing the touch button, the Energy Meter enters the first level of the menu structure. The screen will display 'Measure'.




Step 2 - Go to the 'Reset' Menu

Short touch the touch button 3 times. The screen will display 'Reset'.



Step 3 - Reset All Counters

With the 'Reset' screen showing, move through the menu screens with the Long and Short buttons touches as indicated below



Note that the Counter needs to be Reset **twice** to ensure it is not Reset by mistake

Step 4 - Exit settings menu and return to the main screen

