

File No.: NZSDoC-EDLD63-00

## **New Zealand Supplier Declaration of Conformity (NZSDoC)**

Responsible Supplier Details	nsible Supplier Details	
Name:	Voltex Electrical Ltd	
	92 Vickery Street	
Contact Address:	Te Rapa Hamilton 3200	
	New Zealand	
Telephone:	+64 (7) 847 3060	
Email:	sales@voltexelectrical.co.nz	
New Zealand Company Number:	4314138	
Web:	www.voltexelectrical.co.nz	
Responsible Supplier Code:	E787	

Product Details			
Product type:	LED Emergency Downlight	LED Emergency Downlight	
Product description:	LED Emergency Downlight	LED Emergency Downlight	
Trade name:	<b>VOLTEX</b> <sup>®</sup> (Voltex)		
Item number(s):	EDLD63	EDLD63	
	Input Voltage: 200-240V~ 50Hz	Input Current/Power:	
	Insulation Class: Class II Overvoltage Category: Category II	IP rating: IP20	
Electrical rating:	Luminaire suitable for direct mounting o use; Self-contained luminaire; Non-user LED Emergency Driver - Independent of Constant current type; Class II; non-inher classification; Supply flexible cord with publication; Supply flexible cord with publication; LiFePO4 6.4V, 9.6Wh 1500mAl Designation - X 1 AE 120 (self-container replaceable lamp(s) and/or battery, 2h container supplication - X 1 AEF 120 (self-container supplication - X 1 AEF 120 (self-container supplication - X 1 AEF 120 (self-container supplication).	Round lens - C0: D63; C90: D63	

## Standard(s) applied:

AS 60598.2.22:2019; AS 60598.2.2:2016 +A1 +A2 and AS/NZS 60598.2.2:2001 (New Zealand only Amendment A) with AS/NZS 60598.1:2017 +A1:2017 +A2:2020 AS/NZS 61347.2.7:2019 with AS/NZS 61347.1:2016 +A1:2018 +Rule 1:2020

AS 2293.3:2018 +A1:2021

IEC 62031:2018

IEC TR 62778:2014

AS CISPR 15:2017

	: := *:=: :: : *:=* ::		
	Report/ Certification Number	Date Issued (expiry date)	
	Refer Voltex Electrical Product Compliance Review EPCR-EDLD63-00	11-06-2024	
Relevant Comments and Conditions			
	'Nil'		



File No.: NZSDoC-EDLD63-00

## **New Zealand Supplier Declaration of Conformity (NZSDoC)**

## **Declaration of Conformity**

We Voltex Electrical Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the abovementioned standard(s) or other normative document(s) and have determined that it:
  - Complies with the essential safety characteristics and requirements for electrical equipment set out in AS/NZS 3820; and
  - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Andrew Gore
Position:	Compliance Advisor   Authorised Representative
Date:	11-06-2024
Signature:	Andrew Ngori.