


New Zealand Supplier Declaration of Conformity (NZSDoC)

Responsible Supplier Details

Name:	Voltex Electrical Ltd
Contact Address:	92 Vickery Street Te Rapa Hamilton 3200 New Zealand
Telephone:	+64 (7) 847 3060
Email:	sales@voltexelectrical.co.nz
New Zealand Company Number:	4314138
Web:	www.voltexelectrical.co.nz
Responsible Supplier Code:	E787

Product Details

Product type:	LED Emergency Escape Lighting	
Product description:	Emergency Exit Light	
Trade name:	 (Voltex)	
Item number(s):	EXL and EXLS	
Electrical rating:	Input Voltage: 200-240V~ 50/60Hz	Input Current/Power: 3W Emergency power 1W
	Insulation Class: Class II Overvoltage Category: Category II	IP rating: IP20
	ta: 45°C; Ambient: 0°C to 40°C; RG0 Luminaire suitable for direct mounting on normally flammable surfaces; Luminaire for normal use; Self-contained Emergency Exit Sign; Ceiling or Wall mounting; Fixed wired (terminal block) Non-user replaceable light source, indicator lamps and fuse; Integral controlgear with automatic test function Replaceable battery: LiFePO4 3.2V, 0.6Ah (18650) Designation - X 1 AFG 120 (self-contained, maintained, automatic test gear conforming with IEC 61347-2-7 denoted EL-T, internally illuminated safety sign, Emergency duration: 2 hours)	
Standard(s) applied:		
AS/NZS 60598.2.1:2014+A1:2016+A2:2019 and AS 60598.2.22:2019 with AS/NZS 60598.1:2017+A1:2017+A2:2020 AS/NZS 2293.3:2018+A1:2021 AS/NZS 61347.2.7:2019 with AS/NZS 61347.1:2016 +A1:2018 IEC 62031:2018 IEC TR 62778:2014 AS CSIPR 15:2017		
Report/ Certification Number		Date Issued (expiry date)
Refer Voltex Electrical Product Compliance Review EPCR-EXLx-00		09-07-2024
Relevant Comments and Conditions		
'Nil'		

New Zealand Supplier Declaration of Conformity (NZSDoC)**Declaration of Conformity**

We Voltex Electrical Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the above-mentioned standard(s) or other normative document(s) and have determined that it:
 - Complies with the essential safety characteristics and requirements for electrical equipment set out in AS/NZS 3820; and
 - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Andrew Gore
Position:	Compliance Advisor Authorised Representative
Date:	09-07-2024
Signature:	