


New Zealand Supplier Declaration of Conformity (NZSDoC)

Responsible Supplier Details

Name:	Voltex Electrical Ltd
Contact Address:	92 Vickery Street Te Rapa Hamilton 3200 New Zealand
Telephone:	+64 (7) 847 3060
Email:	sales@voltexelectrical.co.nz
New Zealand Company Number:	4314138
Web:	www.voltexelectrical.co.nz
Responsible Supplier Code:	E787

Product Details

Product type:	Residual Current Device (with integral current protection)
Product description:	Residual current operated circuit breaker with integral overcurrent protection and single fixed value of rated residual operating current.
Trade name:	 (Voltex)
Item number(s):	RCBO*-1-*U series For RCBO*-1-*U series: The 1st '*' denotes the Rated short-circuit capacity in kAmps and can be '4.5' or '6' and the 2nd '*' denotes the rated current in Amps and can be '6', '10', '13', '16', '20', '25', '32' or '40' [RCBO4.5-1-6U, RCBO4.5-1-10U, RCBO4.5-1-13U, RCBO4.5-1-16U, RCBO4.5-1-20U, RCBO4.5-1-25U, RCBO4.5-1-32U and RCBO4.5-1-40U RCBO6-1-6U, RCBO6-1-10U, RCBO6-1-13U, RCBO6-1-16U, RCBO6-1-20U, RCBO6-1-25U, RCBO6-1-32U and RCBO6-1-40U]
Electrical rating:	Ue=230/240V~(1P+N); 50/60Hz In=6, 10, 13, 16, 20, 25, 32 or 40A, B- or C- type curve IΔn=10mA type 1, 30mA, 100mA or 300mA type -A or -AC Ics=Icn=4500A or 6000A, Energy limiting class 3 t≤0.1s DIN Rail mounting; The line and load can be reverse direction
Standard(s) applied:	AS/NZS 61009.1:2015
Report/ Certification Number	Date Issued (expiry date)
Refer Voltex Electrical Product Compliance Review EPCR-RCBOx-1-xU-04	01-03-2022
SAA Approvals CoA number SAA-173158-EA	23-02-2022 (Renewal) (21-12-2027)
Conditions	
Nil	

New Zealand Supplier Declaration of Conformity (NZSDoC)

Declaration

We Voltex Electrical Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the above-mentioned standard(s) or other normative document(s) and have determined that it:
 - Is electrically safe and will continue to meet the relevant standards it has been tested to; and
 - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Andrew Gore
Position:	Compliance & QMS Advisor
Date:	01-03-2022
Signature:	