

**New Zealand Supplier Declaration of Conformity (NZSDoC)**

Responsible Supplier Details	
Name:	Voltex Electrical Ltd
Contact Address:	92 Vickery Street Te Rapa Hamilton 3200 New Zealand
Telephone:	+64 (7) 847 3060
Email:	sales@voltexelectrical.co.nz
New Zealand Company Number:	4314138
Web:	www.voltexelectrical.co.nz
Responsible Supplier Code:	E787

Product Details		
Product type:	Residual Current Device	
Product description:	Residual Current Device without integral overcurrent protection (for household and similar use)	
Trade name:	VOLTEX ® (Voltex)	
Item number(s):	RCD63-2 and RCD63-4 RCD40-2 and RCD40-4	
Electrical rating:	Input Voltage: 230/240V~ (1P+N), 50/60Hz 400/415V~ (3P+N), 50/60Hz Uiimp= 4kV	Input Current/Power: In= 63A, 40A IΔn= 0.03A Type A and AC Im= IΔm= 630A IΔc= Inc= 10,000A
	IP20 (for built in use); Ambient: -5~40°C Independent of the line voltage; Without time delay; Unenclosed; Din rail mounting; Terminal with stirrup, Screw in terminal; Pillar terminal For testing of short-circuit current 10,000A - Grid distance: 45mm	
Standard(s) applied:	AS/NZS 61008.1:2015 +A1:2024: Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs). Part 1: General rules EN IEC 61543:2023+A11:2023/ IEC 61543:2022: Residual current-operated protective devices (RCDs) for household and similar use-Electromagnetic compatibility	
Report/ Certification Number	Date Issued (expiry date)	
Refer Voltex Electrical Product Compliance Review EPCR-RCDx-y-02	05-02-2026	
SAA Approvals, Certificate of Conformity / Approval No.: SAA-202648-EA	27-10-2020 (27-10-2030)	
Relevant Comments and Conditions		
Type AC RCDs are not approved under the NSW Recognised External Approval Scheme		
EESS Platform - Equipment Registration	Length (expiry date)	
E2026002205	5 years (27-10-2030)	

New Zealand Supplier Declaration of Conformity (NZSDoC)

Declaration of Conformity

We Voltex Electrical Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the above-mentioned standard(s) or other normative document(s) and have determined that it:
 - Complies with the essential safety characteristics and requirements for electrical equipment set out in AS/NZS 3820; and
 - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Andrew Gore
Position:	Authorised Representative
Date:	05-02-2026
Signature:	