

10 year lithium battery powered type with wireless interconnect OK for:

QLD

- OK for replacing existing battery operated, and for houses being sold or leased. [Existing 240V must be replaced with 240V]
- NOT OK for new builds or substantial renovations if 240V is available and accessible.

VIC

- NOT OK for buildings constructed after 01/08/1997 if 240V power is available and accessible.
- OK for buildings constructed before 01/08/1997

ACT/NT/SA/NSW/TAS

- OK for replacing existing battery operated, and for houses being sold or leased. [Existing 240V must be replaced with 240V]
- NOT OK for New Builds [Need 240V if available and accessible]

WA

- OK to use ONLY if 240V is not available or accessible

IMPORTANT: *This is a simplified document and provided as an indicative guide only. It must not be relied upon in any way as a substitute for further research, investigation and legal advice. Always check against the latest NCC Building Code of Australia and any other local regulatory provisions.*