




Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that
PROMASTOP® UniCollar®
 for 40-200mm HDPE pipes and 40-160mm uPVC pipes
 has been tested/approved in accordance with
 Australian Standard 1530: Part 4
 methods for fire tests on building materials, components and structures,
 and
 Australian Standard 4072: Part 1
 components for the protection of openings in fire
 resistant separating elements
 (Test/Approval No RIR91611a.2) for up to 4 hours



* For installation onto floor with FRL equal or greater than -/120/120

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776628) Email: mail@promat.com.au Visit: www.promat-ap.com